



| НАЗИВ ПРОСТОРИЈЕ | | | | ПОД | ЗИД | ПЛАФОН | П (m²) |
|------------------|-----------|--|--|------------------------|--------------|-----------|--------|
| 1 | ОСТАВА | | | Кер. плочице | Поликолор | | 14,90 |
| 2 | МАГАЦИН | | | Кер. плочице | Кер. плочице | Поликолор | 9,40 |
| 3 | МАГАЦИН | | | Кер. плочице | Кер. плочице | Поликолор | 9,30 |
| 4 | ОСТАВА | | | Кер. плочице | Поликолор | Поликолор | 11,20 |
| 5 | ОСТАВА | | | Кер. плочице | Поликолор | Поликолор | 11,80 |
| 6 | РАДИОНИЦА | | | Кер. плочице | Поликолор | Поликолор | 42,50 |
| | | | | Укупна нето површина: | | | 99,10 |
| | | | | Укупна бруто површина: | | | 145,80 |

| ROOM | FLOOR | WALL | CEILING | SURFACE (m2) |
|---------------------|---------------|-----------------------|-----------------------|--------------|
| 1. STORAGE ROOM | Ceramic tiles | Semi-dispersive paint | Semi-dispersive paint | 14,90 |
| 2. WAREHOUSE | Ceramic tiles | Ceramic tiles | Semi-dispersive paint | 9,40 |
| 3. WAREHOUSE | Ceramic tiles | Ceramic tiles | Semi-dispersive paint | 9,30 |
| 4. STORAGE ROOM | Ceramic tiles | Semi-dispersive paint | Semi-dispersive paint | 11,20 |
| 5. STORAGE ROOM | Ceramic tiles | Semi-dispersive paint | Semi-dispersive paint | 11,80 |
| 6. WORKSHOP | Ceramic tiles | Semi-dispersive paint | Semi-dispersive paint | 42,50 |
| NET SURFACE TOTAL | | | | 99,10 |
| GROSS SURFACE TOTAL | | | | 145,80 |

| LEGENDA | |
|---------|--|
| | —monofazna utičnica 16A/230V; IP 20 izvod za ključ no h=2,2m |
| | —trofazna utičnica 16A/440V; IP 20 |
| | —monofazna utičnica 16A/230V; IP 20 sa poklopcem |
| | —prekidac jednopolni 10AX/250V; IP 20 |
| | —prekidac serijski 10AX/250V; IP 20 |
| | —prekidac neizmenjeni 10AX/250V; IP 20 |
| | —prekidac unakrsni 10AX/250V; IP 20 |
| | —razvodna tabla izrađena od tvrdog polikarbonata nezapaljivo,elektroizolacionog svojstva IP40 |
| | —prekidac jednopolni sa indikatorom stanja (KIP) 16A/250V; IP 20 |
| | —svetiljka za nu nu rasvetu (antipanik svetiljka) AC 230V/50Hz, sa autonomijom rada >1h sa natpisom "IZLAZ" i strelicom smera kretanja |
| | —sijaljno keramičko gło E27, sa sijalicom 60W |
| | —plafonijera zatvorenog tipa, sa sijaljnrim keramičkim gglom E27, i sijalicom max 75W |
| | —plafonijera zatvorenog tipa, sa sijaljnrim keramičkim gglom E27, i sijalicom max 75W |
| | —bojler izvod kabla PP-Y3x2,5mm2 no visini h=1,7m, dužine 1m |
| | —kutija za izjednačenje potencijala |
| | —reflektor zaokružena armatura 250V 50Hz 125W IP65 |
| | —fluo svetiljka 230V/50Hz 4x18W IP40 sa OPAL difuzorom |
| | —fluo svetiljka 230V/50Hz 3x36W IP46a OPAL difuzorom |
| | —fluo svetiljka 230V/50Hz 4x18W IP40 sa OPAL difuzorom |
| | —fluo svetiljka 230V/50Hz 2x36W IP46a OPAL difuzorom |

| LEGEND OF SYMBOLS | |
|---|--|
| —Single phase outlet, 16A/250V;IP20, outlet for air conditioner, h=2,2m | |
| —Three phase outlet, 16A/440V;IP20 | |
| —Single phase outlet, 16A/250V;IP20, with a cover | |
| —Single pole switch,250A X/250V;IP20 | |
| —Serial switch,250A X/250V;IP20 | |
| —Two-way switch,250A X/250V;IP20 | |
| —Intermediate switch,250A X/250V;IP20 | |
| —Switchboard made of hard polycarbonate, non-inflammable, electro insulation characteristic IP40 | |
| —Single pole switch with indicator,16A/250V;IP20 | |
| —Light for emergency lighting(anti-panic light) AC 230V/50Hz with work autonomy >1h with EXIT label and direction arrow | |
| —Ceramiclampholder E27, with light bulb 60W | |
| —Ceiling light of closed type, with ceramic lampholder E27 and a light bulb max 75W | |
| —Ceiling light of closed type, with ceramic lampholder E27 and a light bulb max 60W | |
| —Hot water heater, cable PP-Y 3X2,5mm2, height h=1,7m, lenght 1m | |
| —Box for equalization of potential | |
| —Flood light, inclined reinforcement 25 50Hz 125W IP 65 | |
| —Fluorescent light 230V/50Hz 4x18W IP 40 with OPAL diffuser | |
| —Fluorescent light 230V/50Hz 3x36W IP 40 with OPAL diffuser | |
| —Fluorescent light 230V/50Hz 4x18W IP 40 with OPAL diffuser | |
| —Fluorescent light 230V/50Hz 2x36W IP 40 with OPAL diffuser | |

| | | |
|-----------------------------------|--|--|
| CHIEF PROJECT ENGINEER | Stanojević B. Dragiša, electrical engineer | "SD ELEKTRO " d.o.o. Izletnička 6 Smederevo Phone: 026/224-011 |
| ASSOCIATE | Burić J. Stevan, electrical engineer | |
| BUILDING | HOSPITAL- ADAPTATION AND REHABILITATION OF THE OLD BUILDING OF PSYCHIATRY DEPARTMENT | |
| CONTENTS OF THE LIST | | Investitor : General Hospital "Sveti Luka" Smederevo |
| DATE | January, 2012 | |
| Electrical system of the basement | | |
| RATIO | 1:50 | Layout number : 10 |

| | | | |
|--|---|---|--|
| Odgovorni projektor tip, el.ing. Stanojević B. Dragiša | | "SD ELEKTRO" d.o.o. Izletnička 6 Smederevo Tel: 026/224-011 | |
| Saradnik: | el.ing. Vurić J. Stevan | | |
| Objekat: | Bošnica – adaptacija i sanacija stare zgrade psihijatrije | | |
| Sadržaj lista: | Elektrifkacione instalacije podruma | | |
| Datum:Jul 2013. | | | |
| Razmjer:1:50 | List broj: 10 | | |