



Municipality Kovacica,
Maršala Tita 50, 26210 Kovačica, Serbia

CLARIFICATIONS 1
RELATED TO TENDER PROCEDURE (QUESTIONS AND ANSWERS)

<i>Programme</i>	<i>Interreg IPA CBC Romania – Serbia Programme</i>
<i>Project title</i>	<i>BANAT GREENWAY CORRIDOR</i>
<i>Name of the Contracting Authority</i>	<i>Municipality Kovacica, Maršala Tita 50, 26210 Kovačica, Serbia</i>
<i>Tender procedure</i>	<i>Equipment-container for bikes hire network point</i>
<i>Reference No</i>	<i>RORS372/KOVACICA/TD 05</i>
<i>Date, Place</i>	<i>13.05.2022, Kovacica</i>

1	Question:
	What are the required door / window dimensions? Is the carpentry glazed?
	Clarification: The container must be equipped with one PVC door posted on a long side with following dimensions: height 190cm-220cm and width 90cm - 120cm. No windows required. (The tender dossier part A: Information for tenderer has been modified and published)
2	Question:
	Is an electrical installation required, and if so, send the specification?
	Clarification: No electrical installation required (The tender dossier part A: Information for tenderer has been modified and published)
3	Question:
	whether additional equipment is needed air conditioning, ventilation or similar.
	Clarification: No additional equipment is needed, such as air conditioning, ventilation or similar (The tender dossier part A: Information for tenderer has been modified and published)
4	Question:
	It would be good to have the technical design of the container you want.
	Clarification: No technical design of the container is available.